COUNTY of KANE PURCHASING DEPARTMENT KANE COUNTY GOVERNMENT CENTER

Theresa Dobersztyn, C.P.M., CPPB Director of Purchasing



December 19, 2017

719 S. Batavia Ave., Bldg. A, 2nd Floor Geneva, Illinois 60134 Telephone: (630)232-5929 Fax: (630) 208-5107

ADDENDUM 4

BID No. & Title: 02-018 SETTLERS HILLS CROSS COUNTRY COURSE

The attention of bidders is called to the following changes, clarifications and/or additions/deletions to the original bid document and they shall be taken into account in preparing the proposal and shall be part of the contract.

CORRECTION

Bid Item #1 – Layout and Staking

Kane County has changed the Construction Staking from Contractor to Engineer but inadvertently left this Bid Item in the revised Offer to Contract Form.

Bid Item #1, shall be deleted from the Bid Items. Vendor to leave it blank or indicate N/A per this bid item.

ADDITIONAL INFORMATION

Pipe Specifications.

High Density Polyethylene (HDPE) Corrugated Plastic Pipe (CPP) shall be dual wall and shall meet the requirements of ASTM F2648 and F477. HDPE CPP shall be rated for H-20 loading with one foot of cover.

Bid due date is December 21, 2017 at 3 p.m., please submit your bid response accordingly and confirm your receipt of Addendum 4.

Sincerely, *Tim Keovongsak, Buyer II* Kane County Purchasing Department